

Does Maretron recomend a particular propane and gas leak detector?

Article Number: 562 | Rating: Unrated | Last Updated: Fri, Jun 6, 2014 6:15 AM

Maretron does not recommend a particular brand propane/gas detector.

The only requirement for a chosen detector is a NO/NC relay output for the device to monitored with a SIM100.

Many detectors offer several options when connecting to an input channel of the SIM100, such as a supervisory relay (see article 483).

Posted - Tue, Nov 13, 2012 3:51 PM. This article has been viewed 2213 times.

Online URL: <https://www.maretron.com/support/knowledgebase/phpkbv7/article.php?id=562>