

## Does Maretron recommend a particular propane and gas leak detector?

Maretron does not recommend a particular brand propane/gas detector.

The only requirement for a chosen detector is a NO/NC relay output for the device to be monitored with a SIM100.

Many detectors offer several options when connecting to an input channel of the SIM100, such as a supervisory relay (see article 483).

Online URL:

<https://www.maretron.com/wp-content/phpkbv96/article.php?id=562>